

lamaPLC Communication: ControlNet

ControlNet is an open industrial network protocol for industrial automation applications known as a fieldbus. ControlNet International earlier supported ControlNet, but in 2008, support and management of ControlNet were transferred to ODVA, which now manages all protocols in the Common Industrial Protocol family.



Features that set ControlNet apart from other field buses include the built-in support for fully redundant cables and the fact that communication on ControlNet can be strictly scheduled and highly deterministic. Due to the unique physical layer, common network sniffers such as Wireshark cannot sniff ControlNet packets. **Rockwell Automation** provides ControlNet Traffic Analyzer software to sniff and analyze ControlNet packets.

Version 1, 1.25 and 1.5

Versions 1 and 1.25 were released quickly when ControlNet first launched in 1997. Version 1.5 was released in 1998, and hardware produced for each variant was typically incompatible. Most installations of ControlNet are version 1.5

Physical layer

ControlNet cables consist of RG-6 coaxial cable with BNC connectors, though optical fiber is sometimes used for long distances. The network topology is a bus structure with short taps. ControlNet also supports a star topology if used with the appropriate hardware. ControlNet can operate with a single RG-6 coaxial cable bus or a dual RG-6 coaxial cable bus for redundancy. In all cases, the RG-6 should be of the quad-shield variety. Maximum cable length without repeaters is 1000m, and a maximum number of nodes on the bus is 99. However, there is a tradeoff between the number of devices on the bus and total cable length. Repeaters can be used to extend the cable length further. The network can support up to 5 repeaters (10 for redundant networks). The repeaters do not utilize network node numbers and are available in copper or fiber optic choices.

The physical layer signaling uses Manchester code at 5 Mbit/s.

Link layer

ControlNet is a scheduled communication network designed for cyclic data exchange. The protocol operates in cycles, known as NUIs, where NUI stands for Network Update Interval. Each NUI has three phases. The first phase is dedicated to scheduled traffic, where all nodes with scheduled data are guaranteed a transmission opportunity. The second phase is dedicated to unscheduled traffic. There is no guarantee that every node will get a chance to transmit in every unscheduled phase. The third phase is network maintenance or "*guardband*". It includes synchronization and determining the starting node for the next unscheduled data transfer. The scheduled and unscheduled phases use an implicit token ring media access method. The amount of time each NUI consists of is known as the NUT, where NUT stands for Network Update Time. It is configurable from 2 to 100 ms. The default NUT

on an unscheduled network is 5 ms.

The maximum size of a scheduled or unscheduled ControlNet data frame is 510 Bytes.

Application layer

The ControlNet application layer protocol is based on the *Common Industrial Protocol (CIP)* layer, which is also used in [DeviceNet](#) and [EtherNet/IP](#).

Sources

Wikipedia ([here](#))

ControlNet topics on lamaPLC

Page	Date	Tags
• lamaPLC Communication: ControlNet	2025/05/31 22:58	bus , communication , devicenet , cip , can , ethernet ip , ethernet , controlnet , mac , peer-to-peer , allen-bradley , rockwell automation , fieldbus , rg-6 , coaxial cable
• lamaPLC Communication: DeviceNet	2024/11/16 19:43	bus , communication , devicenet , 62026-3 , cip , can , ethernet ip , ethernet , controlnet , mac , peer-to-peer , canopen , allen-bradley , rockwell automation , bosch
• lamaPLC Communication: EtherNet/IP	2024/11/17 00:26	communication , ethernet , bus , ip , cip , ethernet ip , udp , industrial ethernet , ie , tcp , unicast , devicenet , controlnet , ieee 802.3

[bus](#), [communication](#), [DeviceNet](#), [CIP](#), [CAN](#), [EtherNet/IP](#), [ethernet](#), [ControlNet](#), [MAC](#), [peer-to-peer](#), [Allen-Bradley](#), [Rockwell Automation](#), [fieldbus](#), [RG-6](#), [coaxial cable](#)

This page has been accessed for: Today: 3, Until now: 120

From: <http://lamaplc.com/> - **lamaPLC**

Permanent link: http://lamaplc.com/doku.php?id=com:basic_controlnet

Last update: **2025/05/31 22:58**

